

ADDENDUM 1
FAN & VFD INSTALLATION RFP 27010
Issued Date: July 14, 2026
Addendum Date: July 21, 2026

This Addendum provides a change regarding the Fan and VFD Installation RFP 27010 issued July 14, 2026.

Change

- The ABB Variable Frequency Drive listed in the RFP for the base bid and option 1 will be changed to the following:
 - **ACH580-VCR-04A8-4**
 - ACH580 drive by ABB
 - 3hp at 480 volt 3 phase
 - 4.8 MAX output amps
 - NEMA 1 Vertical Style enclosure
 - Main Input Circuit Breaker Disconnect with lockable Handle
 - E-Cclipse bypass
 - BacNet MSTP embedded protocol
- This change has also been made on the Attachment A – Proposal Form (included with this addendum).